

Tracking the Sun

The Installed Cost of Photovoltaics
in the U.S. from 1998-2007

Ryan Wiser
Galen Barbose
Carla Peterman

February 2009



Lawrence Berkeley
National Laboratory



Tracking the Sun

The Installed Cost of Photovoltaics in the U.S. from 1998-2007

Primary Authors: Ryan Wiser, Galen Barbose, and Carla Peterman

**Environmental Energy Technologies Division,
Lawrence Berkeley National Laboratory**

Contents

Executive Summary	1
1. Introduction	3
2. Data Summary	5
3. PV Installed Cost Trends	9
Installed Costs Have Declined over Time, but Were Stable from 2005-2007	9
Installed Cost Reductions Are Primarily Associated with Non-Module Costs	10
Historical Cost Reductions Are Most Evident for Systems Smaller than 100 kW	11
The Distribution of Installed Costs Has Narrowed over Time	11
Installed Costs Exhibit Significant Economies of Scale	12
Average Installed Costs Are Lower in Germany and Japan than in the U.S.	14
Installed Costs Vary Widely Across States	15
The New Construction Market Offers Cost Advantages for Residential PV	16
Systems with Thin-Film Modules Had Higher Installed Costs in 2006 and 2007 than Those with Crystalline Modules	18
Module Costs Represent About Half of Total PV Installed Costs, with the Remainder Consisting of a Diversity of Non-Module Cost Components	19
4. PV Incentive and Net Installed Cost Trends	21
State/Utility Cash Incentives Have Declined since 2002	21
Including Federal and State ITCs, Financial Incentives Rose for Commercial PV from 2002-2007, But Fell for Residential PV	23
Declining Financial Incentives for Residential PV Offset Much of the Cost Reductions from 2001-2007, While Net Installed Costs for Commercial PV Continued to Fall	25
Incentives Have Diverged Widely Across States	26
5. Conclusions	29
Appendix	30



Executive Summary

As installations of grid-connected solar photovoltaic (PV) systems have grown, so too has the desire to track the installed cost of these systems over time, by system characteristics, by system location, and by component. This report helps to fill this need by summarizing trends in the installed cost of grid-connected PV systems in the United States from 1998 through 2007.¹ The report is based on an analysis of installed cost data from nearly 37,000 residential and non-residential PV systems, totaling 363 MW of capacity, and representing 76% of all grid-connected PV capacity installed in the U.S. through 2007.

Key findings of the analysis are as follows:²

- Among all PV systems in the dataset, average installed costs – in terms of real 2007 dollars per installed watt (DC-STC) and prior to receipt of any direct financial incentives or tax credits – declined from \$10.5/W in 1998 to \$7.6/W in 2007. This equates to an average annual reduction of \$0.3/W, or 3.5%/yr in real dollars.
- The overall decline in installed costs over time is primarily attributable to a reduction in non-module costs, calculated as the total installed cost of each system minus a global annual average module price index. From 1998-2007, average non-module costs fell from \$5.7/W to \$3.6/W, representing 73% of the average decline in total installed costs over this period. This suggests that state and local PV deployment programs – which likely have a greater impact on non-module costs than on module prices – have been at least somewhat successful in spurring cost reductions.
- Average installed costs have declined since 1998 for systems <100 kW, with systems <5 kW exhibiting the largest absolute reduction, from \$11.8/W in 1998 to \$8.3/W in 2007. Cost reductions for systems >100 kW are less apparent, although the paucity of data for earlier years in the study period may limit the significance of this finding.
- The distribution of installed costs within a given system size range has narrowed significantly since 1998, with high-cost outliers becoming increasingly infrequent, indicative of a maturing market.
- Both the decline in average costs and the narrowing of cost distributions halted in 2005, with average costs and cost distributions remaining essentially unchanged from 2005-2007.
- PV installed costs exhibit significant economies of scale, with systems <2 kW completed in 2006 or 2007 averaging \$9.0/W and systems >750 kW averaging \$6.8/W (i.e., about 25% less than the smallest systems).
- Average installed costs vary widely across states; among systems <10 kW completed in 2006 or 2007, average costs range from a low of \$7.6/W in Arizona (followed by California and New Jersey, which had average installed costs of \$8.1/W and \$8.4/W, respectively) to a high of \$10.6/W in Maryland.
- International experience suggests that greater near-term cost reductions may be possible in the U.S. The average cost of residential PV installations in 2007 (excluding sales/value-added tax) in both Japan (\$5.9/W) and Germany (\$6.6/W) was significantly below that in

¹ Although the report is intended to portray national trends, with 12 states represented within the dataset, the overall sample is heavily skewed towards systems in California and New Jersey, where the vast majority of PV systems in the U.S. have been installed.

² Unless otherwise noted, the results reflect all system types (e.g., rack-mounted, building-integrated, tracking, non-tracking, crystalline, non-crystalline, etc.).

the United States (\$7.9/W). Variations in average installed cost across states, as well as comparisons with Japan and Germany, suggest that markets with large PV deployment programs often tend to have lower average installed costs for residential PV.

- The new construction market offers cost advantages for residential PV; among 1-3 kW systems funded by California's Emerging Renewable Program and completed in 2006 or 2007, PV systems installed in residential new construction cost \$0.6/W less than comparably-sized residential retrofit systems (or \$0.8/W less if focused exclusively on rack-mounted systems).
- Somewhat surprisingly, among systems <10 kW and installed in 2006 or 2007, those with thin-film modules were found to cost \$0.5/W more, on average, than those employing crystalline modules. Among larger systems completed in 2006 or 2007, average installed costs did not differ substantially between crystalline and thin-film systems.
- The limited component-level cost data that are available (for systems <100 kW only) indicate that, on average, module costs represent just over 50% of total installed costs, while inverter costs represent just under 10%. Smaller residential systems are faced with higher overhead, regulatory compliance, and other costs (on a \$/W basis) than are larger systems.
- State and utility cash incentives for PV declined significantly, on average, from 2002 through 2007 across all system size categories. Among systems <5 kW, for example, pre-tax incentives declined from 2002-2007 by an average of \$1.9/W (from \$4.3/W to \$2.4/W).
- As a result of the increase in the Federal investment tax credit (ITC) for commercial systems in 2006, however, total after-tax incentives for commercial PV (i.e., state/utility cash incentives plus state and Federal ITCs, but excluding revenue from renewable energy certificate sales and the value of accelerated depreciation) were \$4.0/W in 2007, an all-time high. Total after-tax incentives for residential systems, on the other hand, averaged \$3.1/W in 2007, their lowest level since 2001. These trends may partially explain the shift towards the commercial sector within the U.S. PV market over this period. Starting in 2009, however, residential PV is likely to receive some gain in overall incentive levels with the lifting of the dollar cap on the Federal residential ITC.
- Due to the overall decline in total after-tax incentives for residential PV from 2001-2007, the net installed cost of residential PV (installed cost minus state/utility cash incentives and tax credits) averaged \$5.1/W in 2007, just 1% less than in 2001. The net installed cost of commercial PV, however, averaged \$3.8/W in 2007, a near-record low and 32% below average net installed costs in 2001.
- Financial incentives and net installed costs diverge widely across states. Among residential PV systems completed in 2007, the combined after-tax incentive ranged from \$2.5/W in Maryland to \$5.7/W in Pennsylvania. These two states also represent the bookends in terms of net installed costs for residential PV, which averaged \$3.2/W in Pennsylvania and \$7.7/W in Maryland. Incentives and net installed costs for commercial systems varied similarly across states.
- Although average installed costs remained flat from 2005-2007, recent developments portend a potentially dramatic shift over the next few years in the customer-economics of PV. Most industry experts anticipate an over-supply of PV modules in 2009, putting downward pressure on module prices, and presumably on total installed costs as well. In addition, the lifting of the cap on the Federal ITC for residential PV, also beginning in 2009, will further reduce net installed costs for residential installations, potentially leading to some degree of renewed emphasis on the residential market in the years ahead.

1. Introduction

Installations of solar photovoltaic (PV) systems have been growing at a rapid pace in recent years. In 2007, 3,400 MW of PV was installed globally, up from 2,200 MW in 2006 and dominated by grid-connected applications. Cumulatively, roughly 10,600 MW of PV was installed worldwide by the end of 2007.³ The United States was the world's fourth largest PV market in terms of annual capacity additions in 2007, behind Germany, Spain, and Japan; 205 MW of PV was added in the U.S. in 2007, 152 MW of which came in the form of grid-connected installations.⁴ Despite the significant year-on-year growth, however, the share of global and U.S. electricity supply met with PV remains small, and annual PV additions are currently modest in the context of the overall electric system.

The market for PV in the U.S. is driven by national, state, and local government incentives, including up-front cash rebates, production-based incentives, requirements that electricity suppliers purchase a certain amount of solar energy, and Federal and state tax benefits. These programs are, in part, motivated by the popular appeal of solar energy, and by the positive attributes of PV – modest environmental impacts, avoidance of fuel price risks, coincidence with peak electrical demand, and the location of PV at the point of use. Given the relatively high cost of PV, however, a key goal of these policies is to encourage cost reductions over time. Therefore, as policy incentives have become more significant and as PV deployment has accelerated, so too has the desire to track the installed cost of PV systems over time, by system characteristics, by system location, and by component.

This report seeks to fill this need by summarizing major trends in the installed cost (i.e., the cost paid by the system owner, prior to the receipt of any available incentives) of grid-connected PV systems in the U.S. from 1998 through 2007.⁵ The report is based on an analysis of project-level cost data from nearly 37,000 residential and commercial PV systems in the U.S., all of which are installed on the utility-customer side of the meter (i.e., “customer-sited” systems). These systems total 363 MW, or 76% of all grid-connected PV capacity installed in the U.S. by the end of 2007, representing the most comprehensive source of installed PV cost data in the United States. In addition to the primary dataset, which is limited to data provided directly by PV incentive program administrators and only includes systems installed on the utility-customer side of the meter, the report also summarizes installed cost data obtained through public data sources for five multi-MW grid-connected PV systems in the U.S. (several of which are installed on the utility-side of the meter). These additional large systems represent a combined 32 MW, bringing the total dataset to 395 MW, or 89% of all grid-connected PV capacity installed in the U.S. through 2007. The report also briefly compares recent PV installed costs in the U.S. to those in Germany and Japan. Finally, it should be noted that the analysis presented here focuses on descriptive trends in the underlying

³ Photon Consulting. 2008. *Solar Annual 2008: Four Peaks*. Boston, Massachusetts. Installed capacity totals refer to power applications, and exclude wafer-integrated products (e.g., electronic devices).

⁴ Sherwood, L. 2008. *U.S. Solar Market Trends 2007*. Interstate Renewable Energy Council. <http://www.irecusa.org>. Note that there is some uncertainty over the correct number for 2007 grid-connected capacity additions in the U.S.

⁵ This report focuses on installed costs paid by the system owner, rather than the costs born by manufacturers or installers. It is possible, especially over the past several years, that cost trends may have diverged between manufacturers and installers, or between installers and system owners. Note also that, in focusing on installed costs, the report ignores improvements in the performance of PV systems, which will tend to reduce the levelized cost of energy of PV even absent changes in installed costs.

data, and is primarily summarized in tabular and graphical form; later analysis may explore some of these trends with more-sophisticated statistical techniques.

The report begins with a summary of the data collection methodology and resultant dataset (Section 2). The primary findings of the analysis are presented in Section 3, which describes trends in installed costs over time, by system size, by state, by application (new construction vs. retrofit), and by technology type (building-integrated vs. rack-mounted and crystalline silicon vs. thin-film). Section 3 also describes trends related to non-module costs and component-level costs, drawing on a limited amount of available component-level cost data and the results of a 2008 survey of PV system installers conducted by Berkeley Lab. Section 4 presents additional findings related to trends in PV incentive levels over time and among states (focusing specifically on state and utility incentive programs as well as state and Federal tax credits), and trends in the net installed cost paid by system owners after receipt of such incentives. Brief conclusions are offered in the final section.

2. Data Summary

This section briefly describes the procedures used to collect, standardize, and clean the data provided by individual PV incentive programs, and summarizes the basic characteristics of the resulting dataset, including: the number of systems and installed capacity by PV incentive program and by year, the sample distribution by state and project size, and the sample size relative to all grid-connected PV capacity installed in the U.S.

Data Collection, Conventions, and Data Cleaning

Requests for project-level installed cost data were sent to state and utility PV incentive program administrators from around the country, with some focus (though not exclusively so) on relatively large programs. Ultimately, 16 PV incentive programs provided project-level installed cost data. To the extent possible, this report presents the data as provided directly by these PV incentive program administrators. That said, several steps were taken to standardize and clean the data, which are briefly summarized here and described in greater detail in Appendix A.

In particular, two key conventions used throughout this report deserve specific mention:

1. All cost and incentive data are presented in real 2007 dollars (2007\$), which required inflation adjustments to the nominal-dollar data provided by PV programs.
2. All capacity and dollars-per-watt (\$/W) data are presented in terms of rated module power output under Standard Test Conditions (DC-STC), which required that capacity data provided by several programs that use a different capacity rating be translated to DC-STC.

Additionally, the data were cleaned by eliminating projects with clearly erroneous cost or incentive data, by correcting text fields with obvious errors, and by standardizing the identifiers for module and inverter models. To the extent possible, each PV system in the dataset was classified as either building-integrated PV or rack-mounted, and as using either crystalline or thin-film modules, based on a combination of information sources. Finally, for many systems in the dataset, data on market sector (e.g., residential, commercial, non-profit) were not provided, in which case systems smaller than 10 kW were assumed to be residential, and those larger than 10 kW were assumed to be commercial.⁶

Sample Description

The final dataset, after all data cleaning was completed, consists of roughly 37,000 grid-connected, residential and non-residential PV systems, totaling 363 MW (see Table 1).⁷ In aggregate, the PV systems in the dataset represent a significant fraction of the U.S. grid-connected PV market, equivalent to approximately 76% of all grid-connected PV capacity installed in the U.S. through 2007, and about 70% of the PV capacity installed in 2007 alone (see Figure 1).⁸ The

⁶ 10 kW is a common, albeit imperfect, cut-off between residential and non-residential PV systems. Among the approximately 9,000 systems in the dataset for which market sector data were provided, 94% of all residential systems were <10 kW, and 43% of commercial systems were >10 kW. If this distribution were applied to the entire dataset (88% of which are residential systems), a total of 12% of all systems would be misclassified using a 10 kW cut-off for residential vs. non-residential systems.

⁷ There may be a moderate level of double-counting of systems between programs, particularly between LADWP's Solar Incentive Program and the ERP and SGIP programs in California, and between the two Illinois programs.

⁸ Sherwood, L. 2008. *U.S. Solar Market Trends 2007*. Interstate Renewable Energy Council. <http://www.irecusa.org>.

largest state markets missing from the primary data sample, in terms of cumulative installed PV capacity through 2007, are: Nevada (representing 4.0% of total U.S. grid-connected PV capacity), Colorado (3.1%), Hawaii (0.9%), and Texas (0.7%).⁹

The primary sample consists only of data provided by PV incentive program administrators, all of which are for systems installed on the utility-customer side of the meter. The report separately describes the installed cost of five multi-MW grid-connected PV systems, several of which are installed on the utility-side of the meter.¹⁰ Cost data for these projects were compiled from press releases and other publicly available sources. The data for these five projects bring the total PV capacity for which cost data are presented to 395 MW, equal to 89% of all grid-connected PV capacity in the U.S. installed through 2007.

Table 1. Data Summary by PV Incentive Program

State	PV Incentive Program	No. of Systems	Total MW	% of Total MW	Size Range (kW)	Year Range
AZ	Solar Partners Incentive Program (Arizona Public Service)	540	3.1	0.9%	0.4 – 255	2002 - 2007
CA	Emerging Renewables Program (California Energy Commission)	27,267	143.0	39.4%	0.1 – 670	1998 - 2007
	Self Generation Incentive Program (Pacific Gas & Electric, Southern California Edison, California Center for Sustainable Energy)	801	132.6	36.5%	34 – 1,265	2002 - 2007
	California Solar Initiative (Pacific Gas & Electric, Southern California Edison, California Center for Sustainable Energy)	2,303	14.3	3.9%	1.2 – 1,182	2007
	Solar Incentive Program (Los Angeles Dept. of Water & Power)	592	10.6	2.9%	0.3 – 467	1999 - 2006
CT	Solar PV and Onsite Renewable DG Programs (Connecticut Clean Energy Fund)	311	2.7	0.7%	1.0 – 434	2003 - 2007
IL	Renewable Energy Grant Programs (Illinois Clean Energy Community Foundation)	21	0.6	0.2%	1.0 – 110	2002 - 2005
	Renewable Energy Resources Rebate Program (Illinois Dept. Commerce & Economic Opportunity)	145	0.7	0.2%	0.8 – 60	1999 - 2007
MA	Small Renewables Initiative (Massachusetts Technology Collaborative)	702	4.7	1.3%	0.2 – 432	2002 - 2007
MD	Solar Energy Grant Program (Maryland Energy Administration)	78	0.2	0.1%	0.5 – 45	2005 - 2007
MN	Solar Electric Rebate Program (Minnesota State Energy Office)	105	0.4	0.1%	0.9 – 40	2002 - 2007
NJ	Customer Onsite Renewable Energy Program (New Jersey Clean Energy Program)	2,395	42.1	11.6%	0.8 – 702	2003 - 2007
NY	PV Incentive Program (New York State Energy Research & Development Authority)	755	4.4	1.2%	0.7 – 51	2003 - 2007

⁹ Some data on larger PV installations in both Colorado and Nevada are included in this report outside of the primary dataset, as summarized in the next paragraph. Additional data from Nevada were provided to Berkeley Lab, but are not included in this report; those data will be included in subsequent updates.

¹⁰ These five systems include: a 14.2 MW system installed in 2007 at Nellis Air Force Base in Nevada; two systems (8.2 MW and 2 MW) installed in Colorado in 2007; and two systems (4.6 MW and 3.4 MW) installed in Arizona, completed in 2004 and 2006, respectively.

OR	Solar Electric Program (Energy Trust of Oregon)	600	2.3	0.6%	0.8 – 67	2003 - 2007
PA	Solar PV Grant Program (Sustainable Development Fund)	137	0.5	0.1%	1.2 – 10	2002 - 2007
WI	Cash Back Rewards Program (Wisconsin Focus on Energy)	240	0.9	0.2%	0.2 – 19	2002 - 2007
Total		36,992	363.1	100%	0.1 – 1,265	1998 - 2007




Figure 1. Data Sample Compared to Total U.S. Grid-Connected PV Capacity¹¹

Table 2. Data Sample by Installation Year

	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	Total
No. of Systems	39	190	219	1,344	2,523	3,471	5,497	5,084	8,353	10,272	36,992
% of Total	0.1%	0.5%	0.6%	3.6%	6.8%	9.4%	14.9%	13.7%	22.6%	27.8%	100%
Capacity (MW)	0.2	0.8	1.0	5.6	14.0	36.0	47.9	61.2	89.3	107.0	363.1
% of Total	0.1%	0.2%	0.3%	1.6%	3.9%	9.9%	13.2%	16.9%	24.6%	29.5%	100%

The PV systems in the primary dataset were installed over a ten-year period, from 1998 through 2007. As to be expected, however, given the dramatic expansion of the U.S. solar market over recent years, the sample is skewed towards projects completed during the latter years of this period (see Table 2). Approximately half of the PV systems in the sample were installed in either 2006 or 2007, and slightly more than half (54%) of the total capacity was installed during these two years.¹² See Appendix B for detailed annual installation data (number of systems and capacity) by PV incentive program and system size range.

Among the 16 PV incentive programs that provided data for this report, the lion's share of the sample is associated with the four largest PV incentive programs in the country to-date: California's Emerging Renewables Program (ERP); California's Self-Generation Incentive Program (SGIP); the California Solar Initiative (CSI) Program; and New Jersey's Customer Onsite Renewable Energy

¹¹ Data source for U.S. Grid-Connected PV Capacity: Sherwood, L. 2008. *U.S. Solar Market Trends 2007*. Interstate Renewable Energy Council. <http://www.irecusa.org>.

¹² Dates used in this report are the system completion dates, or whatever date is provided that best approximates that date.

(CORE) Program. As such, the sample is heavily weighted towards systems installed in California and New Jersey, as shown in Figure 2. In terms of installed capacity, these two states represent 83% and 12% of the total data sample, respectively. Massachusetts, New York, Arizona, Connecticut, and Oregon each represent between 0.6-1.3% of the sample, with the remaining five states (Illinois, Maryland, Minnesota, Pennsylvania, and Wisconsin) comprising 0.9%, in total.

The size of the PV systems in the primary dataset span a wide range, from as small as 100 W to as large as 1.3 MW, but almost 90% of the projects in the sample are smaller than 10 kW (see Figure 3). In terms of installed capacity, however, the sample is considerably more evenly distributed across system size ranges, with systems larger than 100 kW representing 40% of the total installed capacity, and systems smaller than 10 kW representing 38%.




Figure 2. Data Sample Distribution among States (by Cumulative MW)




Figure 3. Data Sample Distribution by PV System Size

3. PV Installed Cost Trends

This section presents the primary findings of the report, describing trends in the average installed cost of grid-connected PV, based on the dataset described in Section 2. It begins by presenting the trends in installed costs over time; by system size; between Japan, Germany, and the U.S.; and among individual states.¹³ It then compares installed costs among several specific types of applications and technologies – specifically, residential new construction vs. residential retrofit, BIPV vs. rack-mounted systems, and systems with thin-film modules vs. those with crystalline modules. Last, the section presents some limited data related to component-level costs. To be clear, the focus of this section is on installed costs, as paid by the system owner, prior to receipt of any financial incentives (e.g., rebates, tax credits, etc.).

Installed Costs Have Declined over Time, but Were Stable from 2005-2007

Figure 4 presents the average installed cost of all projects in the primary sample completed in each year, from 1998-2007. As shown, capacity-weighted average costs declined from \$10.5/W in 1998 to \$7.6/W in 2007, equivalent to an average annual reduction of \$0.3/W, or 3.5%/yr in real dollars.

These cost reductions, however, have not occurred steadily over time. From 1998-2005, average costs declined at a relatively rapid pace, with average annual reductions of \$0.4/W, or 4.8% per year in real dollars. From 2005 through 2007, however, installed costs remained essentially flat. During this period, U.S. and global PV markets expanded significantly, creating shortages in the supply of silicon for PV module production and putting upward pressure on PV module prices. As documented in the next section, however, silicon shortages are not the sole cause for the cessation of price declines during 2005-2007, as average non-module costs also remained relatively flat over this period.




Figure 4. Installed Cost Trends over Time


¹³ Unless otherwise noted, the results include all system types (e.g., rack-mounted, building-integrated, tracking, non-tracking, crystalline, non-crystalline, etc.).

Installed Cost Reductions Are Primarily Associated with Non-Module Costs

Figure 5 disaggregates average annual installed costs into average module and non-module costs. Few programs provided actual component-level cost data. In lieu of this information, Figure 5 presents Navigant Consulting's Global Power Module price index as a proxy for module costs. The non-module costs (which may include such items as inverters, mounting hardware, labor, permitting and fees, shipping, overhead, taxes, and profit) shown in Figure 5 are then calculated as the difference between the average total installed cost and the module price index in each year.

Using this method, the decline in total average PV installed costs since 1998 appears to be primarily attributable to a drop in *non-module* costs, which fell from approximately \$5.7/W in 1998 to \$3.6/W in 2007, a reduction of \$2.1/W (or 73% of the \$2.9/W drop in total installed costs of this period). In comparison, module index prices dropped by only \$0.8/W from 1998-2007, and increased somewhat from 2003-2007.¹⁴ As with the trend in total installed costs, however, average non-module costs remained relatively stable from 2005-2007.

Trends in non-module costs may be particularly relevant in gauging the impact of state and utility PV programs. Unlike module prices, which are primarily established through national (and even global) markets,¹⁵ non-module costs consist of a variety of cost components that may be more readily affected by local programs – including both deployment programs aimed at increasing demand (and thereby increasing competition and efficiency among installers) as well as more-targeted efforts (e.g., training and education programs). Thus, the fact that non-module costs have fallen over time, at least until 2005, suggests (though, admittedly, does not prove) that state and local PV programs have had some success in driving down the installed cost of PV.



Note: Non-module costs are calculated as reported total installed costs minus the global module price index.

Figure 5. Module and Non-Module Cost Trends over Time


¹⁴ Other sources of historical PV module price data are available (e.g., SolarBuzz and Photon Consulting) and show qualitatively similar trends. For example SolarBuzz's retail module price index is approximately \$0.6/W lower in 2007 than at the end of 2001, with relatively constant prices from 2005-2007.

¹⁵ PV modules are effectively commodities whose prices are established through the interplay of global supply and demand. Though average module prices can and do vary by region, those differences are likely to be considerably smaller than differences in non-modules costs.

Historical Cost Reductions Are Most Evident for Systems Smaller than 100 kW

The overall decline in average installed costs across the entire sample largely reflects the decline in costs of small and medium-size systems, as shown in Figure 6. From 1998-2007, the installed cost of systems <5 kW in size dropped from an average of \$11.8/W to \$8.3/W, equivalent to an average annual reduction of \$0.4/W per year. Similar cost reductions occurred for 10-100 kW systems, and lower but still apparent cost reductions occurred for 5-10 kW systems. Larger systems (100-500 kW and >500 kW), however, did not exhibit a discernible reduction in average installed costs over this period.

These trends may, in part, be attributable to the fact that non-module costs, which declined more over time than module costs, comprise a larger portion of the overall cost of smaller systems (as documented later in this report, where component-level cost data are presented for different sizes). Some caution is warranted in interpreting the results for large systems, though, as relatively few of these systems were installed during the early years of the study period. For example, for 100-500 kW systems, fewer than 10 systems were installed each year until 2003; and for >500 kW systems, fewer than 10 systems were installed each year until 2006 (see Table B-2 in Appendix B for annual sample size data by system size).



Note: Averages shown only if more than five observations were available for a given size category in a given year.

Figure 6. Installed Cost Trends over Time, by PV System Size

The Distribution of Installed Costs Has Narrowed Over Time

As indicated by the standard deviation bars in Figure 4, the distribution of installed costs has narrowed considerably over time. This trend can be seen with greater precision in Figures 7 and 8, which present frequency distributions of installed costs for systems less than and greater than 10 kW, respectively, installed in different time periods. Both figures show a marked narrowing of the cost distributions over the past decade. This convergence of prices, with high-cost outliers becoming increasingly infrequent, is consistent with a maturing market characterized by increased competition among installers and module manufacturers, improved module manufacturing and installation efficiency, and better-informed consumers. The two figures also show a *shifting* of the

cost distributions to the left, as would be expected based on the previous finding that average installed costs have declined over time. As with the overall decline in average costs, however, the narrowing of the cost distribution has subsided within the past 3-4 years, with the distribution of installed costs remaining largely stable from 2004/05 to 2006/07.




Figure 7. Distribution of Installed Costs for Systems <10 kW




Figure 8. Distribution of Installed Costs for Systems >10 kW

Installed Costs Exhibit Significant Economies of Scale

Large PV installations may benefit from economies of scale, through price reductions on volume purchases of materials and through the ability to spread fixed costs (including transaction costs) over a larger number of installed watts. This expectation has been borne out in experience, as indicated by Figure 9, which shows the average installed cost according to system size, for PV

systems completed in 2006 and 2007. The smallest systems (<2 kW) exhibit the highest average installed costs (\$9.0/W), while the largest systems (>750 kW) have the lowest average cost (\$6.8/W, or about 25% below the average cost of the smallest systems). Interestingly, the economies of scale do not appear to be continuous with system size, but rather, most strongly accompany increases in system size up to 5 kW, and increases in system size in the 100-750 kW range. In contrast, the data do not show evidence of significant economies of scale within the 5-100 kW size range.

The primary dataset underlying the results shown in Figure 9 consists only of data provided by the 16 PV program administrators in our sample. Not included in this dataset are a number of large, multi-MW PV systems, several of which are installed on the utility-side of the meter. Installed cost data for five of these projects have been reported in press releases and other public sources, and are summarized in Table 3.¹⁶ As shown, the installed costs of these projects are generally similar to the average cost of the >750 kW systems shown in Figure 9.¹⁷ Importantly, though, a number of these out-of-sample multi-MW projects have tracking systems, and are therefore likely to attain higher performance (and thus lower levelized costs on a \$/MWh basis) than the large projects in the primary dataset, which are mostly fixed-axis systems.

To the extent that the economies of scale described above have persisted over time, they may partially explain the temporal decline in average installed costs as the average size of PV systems has grown over time. As shown in Figure 10, the average size of systems <10 kW (a rough proxy for residential systems) grew from 2.7 kW in 1998 to 4.6 kW in 2007. Similarly, the average size of systems >10 kW (most of which are non-residential systems) rose from 25 kW to 55 kW over the same time period.




Figure 9. Variation in Installed Cost According to PV System Size

¹⁶ Table 3 only includes systems >2 MW that are not in the primary dataset and for which installed cost data could be found. Note, though, that the sources of these cost data vary in quality, and therefore these data are less certain than the data in the primary sample.

¹⁷ Though the focus of this report is on systems installed through 2007, it is worth noting that a number of utility-scale PV systems installed in 2008 are reported to have installed costs significantly below the average for >750 kW customer-sited systems installed in 2006/07.

Table 3. Installed Cost of Large PV Systems Not Included in the Primary Dataset

Location	Year of Installation	Plant Size (kW)	Installed Cost (2007\$/W)	Actual or Expected Capacity Factor	Tracking System Design
Nellis, NV	2007	14,200	7.0	24%	single axis
Alamosa, CO	2007	8,220	7.3	24%	fixed, single axis, and double axis
Fort Carson, CO	2007	2,000	6.5	18%	fixed
Springerville, AZ	2001-2004	4,590	5.9	19%	fixed
Prescott Airport, AZ	2002-2006	3,388	5.4	21%	single axis and double axis

Notes: Cost for Springerville is for capacity added in 2004. Cost for Prescott is for single-axis capacity additions in 2004.




Figure 10. PV System Size Trends over Time

Average Installed Costs Are Lower in Germany and Japan than in the U.S.

Notwithstanding the significant cost reductions that have already occurred in the U.S., international experience suggests that greater near-term cost reductions may be possible. Figure 11 compares average installed costs in Japan, Germany, and the United States, focusing specifically on residential systems installed in 2007 (and excluding sales or value-added tax). Among this class of systems, average installed costs were substantially lower in Japan and Germany (\$5.9/W and \$6.6/W, respectively) than in the U.S. (\$7.9/W). These differences may be partly attributable to the much greater cumulative grid-connected PV capacity in Japan and Germany (about 1,800 MW and 3,800 MW, respectively, at the end of 2007), compared to just 500 MW in the U.S. However, it is also evident that larger market size, alone, does not account for all of the variation – as indicated by the fact that installed costs are higher in Germany than in Japan, despite the substantially greater grid-connected PV capacity in the former.¹⁸

¹⁸ The relatively low residential PV costs in Japan may be partly explained by the fact that Japan’s PV support policies have focused largely on the residential sector, and that a large portion of this market consists of pre-fabricated new homes that incorporate PV systems as a standard feature. More generally, installed costs may differ among countries as a result of a wide variety of factors, including differences in: module prices, technical standards for grid-connected PV




Figure 11. Comparison of Average Installed Costs in Japan, Germany, and the U.S. (Residential Systems Completed in 2007)¹⁹

Installed Costs Vary Widely Across States

The U.S. is clearly not a homogenous PV market, as evidenced by Table 4, which compares the average installed cost of systems completed in 2006 or 2007, across the 12 states in the dataset.²⁰ Figure 12 focuses specifically on systems less than 10 kW, for which there are a relatively large number of projects in each state. Among systems in this size class, average costs range from a low of \$7.6/W in Arizona to a high of \$10.6/W in Maryland.

This variation in average installed costs across states is, in part, likely a consequence of the differing size and maturity of the PV markets, where larger markets stimulate greater competition and hence greater efficiency in the delivery chain, and may also allow for bulk purchases and better access to lower-cost products. Most notably, the two largest PV markets in the U.S. – California and New Jersey – have among the lowest average costs, lending some credence to the premise behind state policies and programs that seek to reduce the cost of PV by accelerating deployment.²¹

As noted in the preceding comparison between the U.S., Japan, and Germany, however, other factors also drive differences in installed costs among individual states. Incentive application procedures and regulatory compliance costs, for example, vary substantially. Additionally, installed costs vary across states due to differing sales tax treatment; five of the 12 states shown in Figure 12 (Arizona, Massachusetts, Minnesota, New Jersey, and New York)²² exempted PV hardware costs from state sales tax throughout 2006 and 2007, and Oregon has no state sales tax. If PV hardware costs represent approximately 60% of the total installed cost of residential PV systems (an

systems, installation labor costs, procedures for receiving incentives and permitting/interconnection approvals, foreign exchange rates, and the degree to which components are manufactured locally.

¹⁹ In Figure 11, the Japanese cost data are for 2-5 kW systems, while the German and U.S. cost data are for 3-5 kW systems. Additionally, note that the U.S. data presented in this figure exclude sales tax, and therefore are not entirely comparable to data presented elsewhere in this report, which include sales tax, if applicable. Sources for Japanese and German data: Ikki, O. and K. Matsubara. 2008. *National Survey Report of PV Power Applications in Japan 2007*. Paris, France: International Energy Agency Cooperative Programme on Photovoltaic Power Systems. Wissing, L. 2008. *National Survey Report of PV Power Applications in Germany 2007*. Paris: France: International Energy Agency Cooperative Programme on Photovoltaic Power Systems.

²⁰ See Appendix B for average annual cost data for each of the 16 PV incentive programs.


²¹ The reason for the relatively low average cost in Arizona – itself a smaller PV market – is unknown.

²² Connecticut established a state sales tax exemption for PV beginning in July 2007.

assumption supported by data presented later in this report), sales tax exemptions effectively reduce post-sales-tax installed costs by \$0.2-0.4/W, depending on the state sales tax rate.

Table 4. Average Installed Cost by State and PV System Size Range

State	Total Sample Capacity-Weighted Average Cost		2006-2007 Systems									
			Capacity-Weighted Average Cost (all sizes)		Simple Average Cost							
					0 - 10 kW		10 - 100 kW		100 - 500 kW		>500 kW	
AZ	\$7.8	(n=540)	\$7.6	(n=413)	\$7.6	(n=391)	\$8.1	(n=20)	\$9.1	(n=2)	n/a	(n=0)
CA	\$7.7	(n=30963)	\$7.5	(n=14614)	\$8.1	(n=12850)	\$7.6	(n=1607)	\$7.3	(n=136)	\$6.7	(n=33)
CT	\$8.4	(n=311)	\$8.3	(n=274)	\$8.8	(n=252)	\$8.1	(n=19)	\$7.9	(n=3)	n/a	(n=0)
IL	\$12.4	(n=166)	\$8.5	(n=118)	\$9.8	(n=116)	\$3.3	(n=2)	n/a	(n=0)	n/a	(n=0)
MA	\$9.7	(n=702)	\$9.6	(n=415)	\$9.1	(n=389)	\$10.1	(n=24)	\$8.8	(n=5)	n/a	(n=0)
MD	\$9.8	(n=78)	\$9.7	(n=71)	\$10.6	(n=69)	\$8.5	(n=2)	n/a	(n=0)	n/a	(n=0)
MN	\$8.4	(n=105)	\$8.5	(n=60)	\$8.8	(n=59)	\$8.7	(n=3)	n/a	(n=0)	n/a	(n=0)
NJ	\$7.7	(n=2395)	\$7.5	(n=1588)	\$8.4	(n=1301)	\$8.4	(n=272)	\$7.6	(n=50)	\$6.7	(n=15)
NY	\$8.8	(n=755)	\$8.8	(n=519)	\$8.8	(n=472)	\$8.9	(n=52)	n/a	(n=0)	n/a	(n=0)
OR	\$8.0	(n=600)	\$8.4	(n=324)	\$8.4	(n=305)	\$8.4	(n=19)	n/a	(n=0)	n/a	(n=0)
PA	\$9.0	(n=137)	\$8.7	(n=67)	\$8.7	(n=66)	\$8.4	(n=1)	n/a	(n=0)	n/a	(n=0)
WI	\$8.4	(n=240)	\$8.3	(n=162)	\$8.7	(n=149)	\$7.9	(n=16)	n/a	(n=0)	n/a	(n=0)



Note: Sales tax, if assessed on customer-sited PV installations in 2006-07, was assumed to be applied to only hardware costs, which were assumed to constitute 60% of the total pre-sales-tax installed cost.


Figure 12. Variation in Installed Costs among U.S. States

The New Construction Market Offers Cost Advantages for Residential PV

The California Emerging Renewables Program (ERP) is one of few PV incentive programs within the sample that explicitly tracks which of the funded systems are installed in residential new construction applications.²³ Figure 13 compares the average installed cost of residential new construction and residential retrofit projects funded through the ERP, focusing in particular on 1-3

²³ Note that, starting in 2007, the California Energy Commission's New Solar Homes Program (NSHP) replaced the ERP as the incentive program for PV systems installed in residential new construction (within the service territories of California's investor-owned utilities). No systems funded through the NSHP were completed in 2007, however.

kW projects (the size range typical of residential new construction) completed in 2006 or 2007. Among this group of PV systems, those installed in residential new construction cost \$0.6/W less, on average, than comparably-sized residential retrofit systems (\$7.9/W compared to \$8.5/W), a price advantage of approximately 7%.²⁴



Note : The number of rack-mounted systems plus BIPV systems may not sum to the total number of systems, as some systems could not be identified as either rack-mounted or BIPV.

Figure 13. Comparison of Installed Costs for Residential Retrofit vs. New Construction

Simply comparing the overall average cost of all residential new construction and all residential retrofit systems masks the fact that a much larger proportion of new construction systems are building-integrated PV (BIPV), which tend to have somewhat higher costs than rack-mounted systems, though the higher installed costs may be partially offset by avoided roofing material costs. To allow an apples-to-apples comparison, Figure 13 also presents average costs for rack-mounted and BIPV systems within both the new construction and retrofit samples. Systems were identified as BIPV or rack-mounted based on module manufacturer and model data provided for the ERP-funded systems. These comparisons suggest a somewhat greater cost advantage for new construction than implied by the overall averages, with rack-mounted systems installed in residential new construction averaging \$0.8/W less than residential retrofit systems (\$7.7/W compared to \$8.5/W), and BIPV systems in new construction averaging \$1.1/W less than residential retrofits (\$8.3/W compared to \$9.4/W).²⁵

²⁴ For this report, we have not attempted to distinguish between PV systems installed in large new residential developments and those installed on individual custom new homes. This issue was explored in a previous Berkeley Lab report: Wiser, R., M. Bolinger, P. Cappers, and R. Margolis. 2006. *Letting the Sun Shine on Solar Costs: An Empirical Investigation of Photovoltaic Cost Trends in California*. LBNL-59282. Berkeley, California: Lawrence Berkeley National Laboratory. That earlier report used data from the ERP and a multi-variate linear regression analysis, and found that the cost differential between residential new construction and retrofit markets was much greater for large new developments than for individual new homes. Specifically, PV systems installed in large new residential developments were found to cost \$1.2/W_{AC} (\$1.0/W_{DC-STC}) less, on average, than residential retrofit systems, while systems installed on individual new homes cost just \$0.18/W_{AC} (\$0.15/W_{DC-STC}) less than retrofit systems.

²⁵ Some caution is warranted in interpreting the cost comparison for BIPV systems. Individual PV systems in the ERP dataset were identified as BIPV using module manufacturer and model data provided for these systems. Because some

Small Systems with Thin-Film Modules Had Higher Installed Costs in 2006 and 2007 than Those with Crystalline Modules

Module manufacturer and model data were provided for approximately half of the systems in the dataset, and were used to determine whether these systems employed thin-film or crystalline modules.²⁶ As shown in Figure 14, thin-film systems <10 kW in size and installed in 2006 or 2007 had average installed costs \$0.5/W higher than comparably-sized crystalline systems.²⁷ This result comes as somewhat of a surprise given that thin-film modules are widely considered to be lower cost than crystalline, and that greater uncertainty in the long-term performance of thin-film modules, on the part of consumers, would seemingly tend to drive down the price of thin-film systems relative to their crystalline counterparts. One potential explanation may be that the lower efficiency of thin-film modules leads to higher balance of system costs, at least among the systems in our sample, and therefore higher total installed costs.

Among larger systems, average installed costs did not vary substantially between those employing thin-film modules and those with crystalline modules. Within the >100 kW size category shown in Figure 14, thin-film systems appear to be substantially more costly than crystalline systems (\$7.7/W, compared to \$7.1/W for crystalline systems). However, this apparent trend is an artifact of the small sample size and the presence of a single thin-film system with an installed cost of \$25/W. If this system were eliminated from the data set, the average cost of the thin-film systems >100 kW would be \$7.2/W – only marginally higher than the corresponding value for crystalline systems.




Figure 14. Comparison of Installed Costs for Crystalline vs. Thin-Film Systems

modules made for BIPV applications may be installed as rack-mounted systems, it is possible (if not likely) that some of the systems identified as residential retrofit BIPV systems may be misclassified and may, in fact, be rack-mounted installations.

²⁶ Thin-film systems include both amorphous silicon and non-silicon modules.

²⁷ For the purpose of this comparison, we compare rack-mounted crystalline to rack-mounted thin-film (i.e., we exclude BIPV systems).

Module Costs Represent About Half of Total PV Installed Costs, with the Remainder Consisting of a Diversity of Non-Module Cost Components

The average module and non-module costs presented previously in Figure 5 were estimated based on a module price index. This approach was necessitated by the fact that many of the PV incentive programs in our data sample did not provide component-level cost data. However, a few programs did provide component-level cost data, and this limited quantity of data do lend some validation to the break-down between module and non-module costs implied in Figure 5, and also provide a moderate level of additional detail on the composition of non-module costs. Figure 15 summarizes the limited amount of component-level cost data provided by the PV incentive programs in our data sample, for <10 kW and 10-100 kW systems completed in 2006-2007. For both system size ranges, modules represent slightly over 50% of total costs, on average – which is roughly consistent with the imputed module cost indicated in Figure 5 – while inverter costs average just under 10% of total costs. “Other” costs (e.g., mounting hardware, labor, overhead, profit, etc.) make up the relatively substantial remaining portion of total installed costs.

Some additional detail on individual component costs, although not based directly on project data, can be gleaned from the results of a survey of PV installers conducted by Berkeley Lab in 2008. The survey asked installers to provide the typical percentage contribution to total cost for a variety of specific cost components (e.g., modules, inverters, installation labor, etc.). As shown in Figure 16, installers reported that module costs typically represent approximately 50% of total installed cost, and inverters represent 6-7% of total costs – findings that are generally consistent with the component cost data reported by PV incentive program administrators, which are based on actual system installations. The survey results also provide further granularity in decomposing non-module, non-inverter costs. In particular, the survey results indicate that, depending on the system size, installation labor represents 9-10% of total installed cost, and other materials (e.g., mounting hardware) represent 7-11% of installed cost. The remaining 20-29% of installed costs consists of overhead, profit, and regulatory compliance (e.g., permitting, interconnection, rebate application). Not surprisingly, these “other” costs – many of which are largely fixed costs – represent a greater percentage of total installed costs for residential systems than for larger, non-residential systems.





Figure 15. Module, Inverter, and Other Costs



Sample size: six installers provided survey responses for residential and large commercial systems, and five installers provided survey responses for small commercial systems.

Figure 16. Results from Berkeley Lab Survey of PV Installers on Component Costs

4. PV Incentive and Net Installed Cost Trends

Financial incentives provided through utility, state, and Federal programs have been a major driving force for the PV market in the U.S. These incentives potentially include some combination of cash incentives provided through state or utility PV incentive programs, Federal and/or state investment tax credits (ITCs), revenues from the sale of renewable energy certificates (RECs), and accelerated depreciation of capital investments in solar energy systems. This section describes trends in incentive levels (focusing specifically on state/utility incentives and ITCs) and net installed costs (i.e., installed costs after receipt of financial incentives) over time, by system size, and among states.

Two important caveats should be noted at the outset:

- First, the set of incentives addressed here are necessarily limited in scope, accounting only for the direct cash incentives provided through the 16 state/utility incentive programs in the dataset, plus state and Federal ITCs. The analysis does not account for the incentive for commercial PV provided through accelerated depreciation (which has remained constant over the sample period),²⁸ nor for any additional incentives that projects may have received from state/utility incentive programs outside of the 16 program covered in this report.²⁹ The results presented in this section also do not account for revenue from the sale of RECs, although the potential magnitude of this revenue stream is briefly discussed in general terms (see Text Box 1).
- Second, this section marks a departure from Section 3 by going beyond a simple reporting of the data provided by program administrators. In particular, a variety of assumptions, as documented within this section and described further in Appendix C, were required in order to estimate the value of Federal and state ITCs for each project and to determine the net installed cost on an after-tax basis.

State/Utility Cash Incentives Have Declined since 2002

The 16 state and utility PV incentive programs represented within the dataset provide cash incentives of varying forms. Most provide up-front cash incentives (i.e., “rebates”), based either on system capacity, a percentage of installed cost, or a projection of annual energy production. Several programs, instead, provide performance-based incentives (PBIs), which are paid out over time based on actual energy production, as either a supplement or an alternative to an up-front rebate.³⁰ Figure 16 shows the average cash incentive, on a \$/W basis, received by the PV systems in the dataset, over time and according to system size. These data are presented on a *pre-tax* basis – that


²⁸ Commercial PV owners are allowed to depreciate the installed cost of their system over a 5-year schedule, rather than the standard 20-year period. The net present value of this accelerated depreciation (relative to the standard depreciation schedule) is equal to 12% of installed costs. See: Bolinger, M., G. Barbose, and R. Wiser. 2008. *Shaking Up the Residential PV Market: Implications of Recent Changes to the ITC*. Berkeley, CA: Lawrence Berkeley National Laboratory.

²⁹ For example, in Pennsylvania, some projects may have received incentives through both the Sustainable Energy Fund’s Solar Grant Program and the state’s Energy Harvest Program (where the former is included in the dataset and the latter is not).

³⁰ PBI payments were reported by PV incentive program administrators on a \$/W basis, based on estimated energy production. These \$/W figures were used directly, without discounting, in the analysis provided in this section.

is, prior to assessment of state or Federal taxes that may be levied if the incentive is treated as taxable income.³¹

As shown, average cash incentives declined significantly from 2002-2007 across all size ranges (with the exception of the >500 kW category, for which insufficient data are available for 2002). Specifically, cash incentives declined from 2002-2007 by an average of \$1.9/W for systems in the <5 kW, 5-10 kW, and 10-100 kW size ranges, and by \$1.4/W for systems 100-500 kW.³² These trends largely reflect changes in incentive levels within California’s Emerging Renewables Program (ERP) and Self-Generation Incentive Program (SGIP), which together represent approximately 75-80% of all systems in each size category. To some extent, these incentive level trends also reflect the growing prominence of New Jersey’s Customer-Onsite Renewable Energy (CORE) program, which has offered relatively high incentives. The CORE program represents an increasing percentage of the sample in all size categories over time, counteracting, to some degree, the decline in average incentive levels associated with the drop in ERP and SGIP incentives. Although masked by the dominant effect of the California and New Jersey programs, average incentives among the other PV incentive programs also generally declined since 2002/2003 (see Table B-3 in Appendix B). Last, it is perhaps interesting to note that, although the difference is relatively small, the largest systems in the sample (>500 kW) received the highest incentives, on average, in 2007 (\$2.9/W), while the smallest systems (< 5 kW) received the lowest average incentives in that year (\$2.4/W).



Note: Averages shown only if more than five observations available for a given size range in a given year.

Figure 16. Pre-Tax State/Utility Cash Incentive Levels over Time

³¹ Although the IRS has provided only limited guidance on the issue, it appears that, in most cases, cash incentives provided for commercial PV systems are considered Federally-taxable income. Cash incentives for residential PV, however, are exempt from Federal income taxes if the incentive is considered to be a “utility energy conservation subsidy,” per Section 136 of the Internal Revenue Code. Despite several IRS private letter rulings of potential relevance, uncertainty remains as to what exactly constitutes a “utility energy conservation subsidy.” See: Bolinger, M., G. Barbose, and R. Wiser. 2008. *Shaking Up the Residential PV Market: Implications of Recent Changes to the ITC*. Berkeley, CA: Lawrence Berkeley National Laboratory.

³² For systems >500 kW, the maximum average incentive was \$3.6/W in 2004, declining to \$2.9/W in 2007 (a drop of \$0.7/W). However, fewer than 10 systems in this size range were installed each year prior to 2006, and therefore the time trend is rather idiosyncratic and not particularly meaningful.

Text Box 1. Revenue from the Sale of RECs

PV system owners may be able to sell RECs generated by their system, adding to any direct incentives received from state/utility PV incentive programs and Federal or state ITCs (provided that REC ownership is not automatically transferred to the state/utility as a condition of receiving a direct cash incentive). Projecting the value of REC sales over the lifetime of each individual PV system in our dataset would be a highly speculative task, and therefore was not undertaken for this study. Based on historical REC prices, however, the revenue potential in most states (with the exception of New Jersey) is relatively modest, compared to the value of direct cash incentives received through state/utility PV incentive programs and to the value of the Federal ITC for commercial PV.


In general, the potential REC revenue for customer-sited PV depends on where the system is located, and consequently, what types of REC markets are available.

- *Voluntary REC Markets.* In most states, RECs generated by PV systems may be sold to individuals, businesses, or government agencies that are voluntarily seeking to support renewable energy and/or to publicly demonstrate their support. Given the voluntary nature of these transactions, prices in voluntary REC markets have historically been quite modest. For example, voluntary RECs traded through Evolution Markets, a brokerage firm, averaged about \$20/MWh in 2007. Extrapolated over a 20-year period, revenues from REC sales at this price are equivalent to just \$0.23/W on a present value basis (assuming a 10% nominal discount rate and a capacity factor of 14%), without accounting for income tax that may be assessed on REC revenue.
- *Traditional RPS Markets.* In some states, RECs generated by PV systems may be sold to electricity suppliers for compliance with state renewables portfolio standards (RPS). These markets may offer greater REC revenue potential, though REC prices in RPS markets have historically varied quite substantially across states and over time. For PV, the most critical issue typically is whether the state RPS has a specific solar requirement (i.e., a “solar set-aside”). In traditional RPS markets without a solar set-aside, the highest average REC prices in 2007 (based on trading through Evolution Markets) occurred in Massachusetts, where REC prices for compliance with the state’s Class I RPS requirement averaged approximately \$55/MWh. Extrapolating these prices over a 20-year period (using the same assumptions as before) is equivalent to an up-front, pre-tax payment of \$0.63/W.
- *RPS Solar Set-Aside Markets.* Substantially greater REC revenue potential may be available in states with an RPS solar set-aside. Through 2007, active trading of solar RECs (or SRECs) for compliance with a solar set-aside occurred primarily in New Jersey, where SRECs traded through Evolution Markets averaged \$253/MWh in 2007. Again, extrapolating this revenue stream over a 20-year period yields the equivalent of an up-front, pre-tax payment of \$2.9/W (equal to roughly 60% of the average pre-tax cash incentive paid by New Jersey’s CORE Program for PV systems installed in 2007). As of 2009, however, systems larger than 50 kW in New Jersey are no longer eligible for cash incentives, as the state shifts towards an SREC-based support mechanism.

Including Federal and State ITCs, Financial Incentives Rose for Commercial PV from 2002-2007, But Fell for Residential PV

Although direct cash incentives received from state and utility PV programs have, on average, declined over time, other sources of financial incentives have become more significant. Most notably, starting January 1, 2006, the Federal ITC for commercial PV systems rose from 10% to 30% of project costs, and a 30% ITC (capped at \$2,000) was established for residential PV. (Note that the *Energy Improvement and Extension Act of 2008* lifted the cap on the residential ITC for

systems installed on or after January 1, 2009; however, this change does not pertain to the systems within our sample.) In addition to the Federal ITC, a number of states have, at various times, also offered state ITCs for PV, although these tax credits have generally been smaller and/or available to a more-restricted set of projects than the Federal tax credit (see Appendix C for details on the ITCs for PV offered by the states in our dataset).



Notes: We assume that all systems <10 kW are residential (unless identified otherwise) and that state/utility cash incentives for such systems are non-taxable and reduce the basis of the Federal ITC. We assume that all systems >10 kW are commercial (unless identified otherwise) and that state/utility cash incentives for such systems are taxed at a Federal corporate tax rate of 35% plus the prevailing state corporate tax rate, and do not reduce the basis of the Federal ITC. The value of state ITCs is calculated as described in Appendix C.

Figure 17. After-Tax State/Utility Cash Incentives plus State & Federal ITCs (Estimated)

Figure 17 illustrates the combined effect of changes over time in state and Federal ITCs (assuming that all customers take advantage of available tax credits) *plus* changes in the cash incentives provided through the state and utility PV incentive programs in the dataset, expressed here on an *after-tax* basis. As noted previously, this assessment ignores potential revenues from the sale of RECs, though for most of the 12 states in our dataset (other than New Jersey), such revenues would likely add only marginally to the overall incentive received (see Text Box 1).

Figure 17 suggests a notably different trend for commercial PV systems than that exhibited in Figure 16 for systems >10 kW (the majority of which are commercial). Specifically, as shown in Figure 17, the decline in the average combined commercial incentive that began in 2002 abruptly reversed course in 2006, when the Federal ITC for commercial PV increased from 10% to 30% of project costs. As a result, commercial PV systems received *greater* total financial incentives in 2006-2007, on average, than at any time since 1998, with the after-tax value of cash incentives plus ITCs averaging \$4.0/W in 2007. Residential PV also saw a slight boost in overall incentive levels when the Federal ITC was extended to these systems in 2006; however, with the \$2,000 cap on the residential credit, the effect was much less dramatic than for commercial PV.³³ Consequently, the

³³ Removal of the \$2,000 ITC cap for residential systems installed on or after January 1, 2009 will, of course, provide an additional increase in residential incentives. Even after the cap is lifted, however, the average value of the residential ITC will still be less than the commercial ITC, because utility rebates for residential systems are often tax-exempt and therefore reduce the tax credit basis on which the ITC applies.

combined after-tax incentive (cash incentives plus ITCs) for residential PV was, in 2007, at its lowest average level (\$3.1/W) since 2001.

The fact that combined after-tax incentives rose substantially from 2005-2007 for commercial PV, while remaining essentially flat for residential PV, may partially explain the shift towards the commercial sector within the U.S. PV market over this period. With the lifting of the cap on the Federal ITC for residential PV beginning in 2009, however, some movement back towards the residential sector may occur.


Declining Financial Incentives for Residential PV Offset Much of the Cost Reductions from 2001-2007, While Net Installed Costs for Commercial PV Continued to Fall

As discussed at length in Section 3, average installed costs across most PV system size categories declined significantly from 1998-2005, but remained relatively stable from 2005-2007. At the same time, average after-tax incentive levels for residential systems steadily declined from 2002-2007. The net effect of these two trends, as illustrated in Figure 18, is that the net installed cost of residential PV – that is, the installed cost after deducting the after-tax value of state/utility cash incentives plus ITCs – has remained relatively flat since 2001, declining by \$0.8/W from 2001-2004, and then increasing by \$0.6/W from 2004-2007. Thus, in 2007, the average net installed cost of residential PV was \$5.1/W, compared to an average of \$5.3/W in 2001, a drop of just 1%.

As shown in Figure 19, the trend for commercial PV is markedly different, by virtue of the more-lucrative Federal ITC available beginning in 2006. Specifically, in 2007, the net installed cost of commercial PV was \$3.8/W, compared to \$5.6/W in 2001, a drop of 32%. Without Federal and state ITCs, though, the average net installed cost of commercial PV would be only 10% lower in 2007 than in 2001 (\$6.3/W compared to \$7.0/W), and would be essentially unchanged from the average net installed cost in 2003 (\$6.2).


Finally, Figures 18 and 19 also illustrate the potential impact of incentive levels on gross (i.e., pre-incentive) installed costs. A previous Berkeley Lab report, *Letting the Sun Shine on Solar Costs: An Empirical Investigation of Photovoltaic Cost Trends in California*, found a statistically significant correlation between pre-incentive installed costs in California and incentive levels under the state's two major PV incentive programs at the time (ERP and SGIP).³⁴ Evidence of this correlation can be seen in Figures 18 and 19 (not surprisingly so, given the dominance of ERP and SGIP systems within the dataset). Most visibly, the decline in gross installed costs that had occurred during prior years ceased in 2001-2002, especially among commercial systems, coinciding with a substantial increase in incentive levels under the ERP and SGIP.

³⁴ Wisner, R., M. Bolinger, P. Cappers, and R. Margolis. 2006. *Letting the Sun Shine on Solar Costs: An Empirical Investigation of Photovoltaic Cost Trends in California*. LBNL-59282. Berkeley, California: Lawrence Berkeley National Laboratory.



Notes: We assume that all systems <10 kW are residential (unless identified otherwise) and that state/utility cash incentives for such systems are non-taxable and reduce the basis of the Federal ITC. The value of state ITCs is calculated as described in Appendix C.

Figure 18. Net Installed Cost of Residential PV over Time (Estimated)



Notes: We assume that all systems >10 kW are commercial (unless identified otherwise) and that state/utility cash incentives for such systems are taxed at a Federal corporate tax rate of 35% plus the prevailing state corporate tax rate, and do not reduce the basis of the Federal ITC. The value of state ITCs is calculated as described in Appendix C.

Figure 19. Net Installed Cost of Commercial PV over Time (Estimated)


Incentives Have Diverged Widely Across States

The preceding time trends apply to the sample at large, which is itself dominated by the PV incentive programs in California and New Jersey. Of course, incentives and net installed costs vary significantly from state-to-state, as shown in Figures 20 and 21, which compare average incentive levels and net installed costs across the 12 states in our dataset, focusing specifically on systems

installed in 2007.³⁵ Again, note that this analysis does not capture all types of financial incentives that may be available to PV systems in each state (e.g., incentives offered by other PV incentive programs outside of the 16 programs included in the data sample, and revenue that may be available from the sale of RECs).

Among residential systems installed in 2007 (Figure 20), average after-tax incentives (i.e., the sum of direct cash incentives from state/utility PV incentive programs plus state and Federal ITCs, but excluding revenue from sale of RECs) ranged from a high of \$5.7/W in Pennsylvania to just \$2.5/W in Maryland. These two states also represent the bookends in terms of net installed cost after incentives, averaging \$3.2/W and \$7.7/W, respectively. The largest PV markets, California and New Jersey, also fall at opposite ends of the spectrum. In California, after-tax incentives for residential PV averaged \$2.8/W in 2007, yielding an average net installed cost of \$5.4/W. In New Jersey, which offered a much more lucrative cash incentive in 2007, the combined after-tax incentive for residential PV averaged \$5.1/W, yielding an average net installed cost of \$3.3/W.


For commercial PV (Figure 21), average after-tax incentive levels and net installed costs also varied considerably across states in 2007. Comparing only those states for which the data sample contained five or more commercial systems completed in 2007 (which excludes Pennsylvania and Maryland, the two bookends from the residential comparison, as well as Illinois), average after-tax incentives for commercial PV in 2007 ranged from \$6.2/W in Oregon to \$3.7/W in California. The lowest average net installed cost belongs to Oregon, at \$2.7/W (not accounting for SRECs, which, as discussed in Text Box 1, could reduce net installed costs in New Jersey by a substantial additional amount, potentially making it the state with the lowest net installed costs for commercial PV in 2007). In comparison, the net installed cost of commercial PV in 2007 was greatest in Minnesota, at \$5.4/W.



Notes: We assume that all systems <10 kW are residential (unless identified otherwise) and that state/utility cash incentives for such systems are non-taxable and reduce the basis of the Federal ITC. The value of state ITCs is calculated as described in Appendix C.

Figure 20. Comparison of Incentive Levels and Net Installed Cost across States for Residential PV Systems Installed in 2007 (Estimated)

³⁵ See Appendix B for data on the average annual cash incentive for each of the 16 PV incentive programs.



Notes: IL, MD, and PA are omitted from the figure due to insufficient sample size (<5 systems). We assume that all systems >10 kW are commercial (unless identified otherwise) and that state/utility cash incentives for such systems are taxed at a Federal corporate tax rate of 35% plus the prevailing state corporate tax rate, and do not reduce the basis of the Federal ITC. The value of state ITCs is calculated as described in Appendix C.

Figure 21. Comparison of Incentive Levels and Net Installed Cost across States for Commercial PV Systems Installed in 2007 (Estimated)

5. Conclusions

Installations of photovoltaic systems have been growing at a rapid pace in recent years, driven in large measure by government incentives. Given the relatively high cost of PV, a key goal of these policies has been to encourage cost reductions over time. Out of this goal arises the need for reliable information on the historical installed cost of PV. This report addresses this need, describing trends in the installed cost of approximately 37,000 grid-connected systems deployed across 12 states from 1998-2007.

Available evidence confirms that PV costs have declined substantially over time, especially among smaller systems, primarily as a result of reductions in non-module costs. This trend, along with the narrowing of cost distributions over time, suggests that PV deployment policies have achieved some success in fostering competition within the industry and in spurring improvements in the cost structure and efficiency of the delivery infrastructure. Moreover, the fact that states with the largest PV markets also appear to have somewhat lower average costs than most states with smaller markets lends further credence to the premise that state and utility PV deployment policies can affect local costs. Even lower average installed costs in Japan and Germany suggest that deeper near-term cost reductions may be possible.

Despite these findings, both module and non-module costs remained largely unchanged from 2005-2007, perhaps reflecting constraints throughout the supply-chain and delivery infrastructure as PV markets rapidly expanded. This trend, were it to continue indefinitely, would be cause for concern, given the desire of PV incentive programs to continue to ratchet down the level of financial support offered to PV installations. Recent developments, however, portend a potentially dramatic shift over the next few years, with significant improvements in the customer-economics of PV. First, in contrast to the recent past, most industry experts anticipate an over-supply of PV modules in the near future, putting downward pressure on module prices in 2009 and, hence, on total installed costs (though projections of the magnitude of these price reductions vary considerably). Second, the lifting of the cap on the Federal ITC for residential PV, also beginning in 2009, will further reduce net installed costs for residential installations (to the extent that it is not offset by corresponding reductions in state and utility incentives). Although large commercial PV installations may continue to be the dominant growth market (joined by utility-scale PV), the removal of the cap on the residential ITC may lead to some degree of renewed emphasis on the residential market in the years ahead.

Appendix A: Data Cleaning, Coding, and Standardization

To the extent possible, this report presents the data as provided directly by PV incentive program administrators. That said, several steps were taken to clean the data and standardize it across programs, described below.

Projects Removed from the Dataset: The initial data sample received from PV incentive program administrators consisted of 37,249 PV systems installed through 2007. To eliminate presumably erroneous numerical data entries, systems were removed from the dataset if the reported installed cost was less than \$3/W (13 systems) or greater than \$30/W (28 systems), or if the incentive amount was zero (27 systems) or greater than the installed cost (17 systems). In addition, systems missing installed cost data (31 systems), incentive data (6 systems), or system size data (71 systems) were removed from the dataset. Finally, 74 systems with battery back-up were removed from the dataset. In total, 267 systems, out of an initial sample of 37,185, were removed from the dataset as a result of these filters, yielding a final sample of 36,992 systems.

Manual Data Cleaning: City, installer, zip code, module manufacturer/model, and inverter manufacturer/model data were reviewed in order to correct obvious misspellings and misidentifications, and to create standardized identifiers for individual module and inverter models.

Completion Date: The data provided by several PV incentive programs did not identify the system completion date. In lieu of this information, the best available proxy was used (e.g., the date of the incentive payment or the post-installation site inspection).

Identification of Residential New Construction and Residential Retrofit Systems: Section 3 compares the cost of systems installed in residential new construction to those installed in residential retrofit applications, focusing specifically on 1-3 kW systems funded through the California Energy Commission (CEC)'s Emerging Renewables Program (ERP) and installed in 2006 or 2007. Residential new construction systems were identified within the ERP dataset if the data field labeled "Category" contained the value "Development," "New Home," or "n".

Identification of Building-Integrated and Rack-Mounted Residential Systems: The comparison between residential new construction and residential retrofit systems funded through the ERP is further differentiated between building-integrated PV (BIPV) and rack-mounted systems. The raw data provided by the CEC did not include explicit identifiers for these categories; thus, systems were identified as either BIPV or rack-mounted by cross-referencing data provided on the module manufacturer and model for each system with the California Solar Initiative (CSI)'s List of Eligible Modules, which explicitly identifies whether modules are BIPV or rack-mounted.³⁶ Based on this procedure, 2,835 of the 2,879 applicable systems (i.e., 1-3 kW systems funded through the ERP in 2006 or 2007) were identified as either BIPV or rack-mounted.

Identification of Crystalline and Thin-Film Systems: Section 3 compares the installed cost of systems with thin-film modules to those with crystalline modules. The raw data provided by PV program administrators generally do not include explicit identifiers for these categories. Thus, systems were categorized as thin-film or crystalline by cross-referencing data provided on module manufacturer and model with the CSI's List of Eligible Modules, which explicitly identifies whether modules are crystalline or thin-film. Based on this procedure, 32,035 of the 36,992 systems were identified as employing either thin-film or crystalline modules.

³⁶ <http://www.gosolarcalifornia.org/equipment/pvmodule.php>

Conversion to 2007 Real Dollars: Installed cost and incentive data are expressed throughout this report in real 2007 dollars (2007\$). Data provided by PV program administrators in nominal dollars were converted to 2007\$ using the “Monthly Consumer Price Index for All Urban Consumers,” published by the U.S. Bureau of Labor Statistics.

Conversion of Capacity Data to DC Watts at Standard Test Conditions (DC-STC): Throughout this report, all capacity and dollars-per-watt (\$/W) data are expressed using DC-STC capacity ratings. Most of the capacity data were already provided in units of DC-STC; however, two programs (California’s Emerging Renewables Program and Self-Generation Incentive Program) provided capacity data only in terms of the CEC-AC rating convention. Capacity data from these two programs were converted to STC-DC, according to the procedures described below.

Emerging Renewables Program (ERP): The data provided for the ERP included data fields identifying the module manufacturer, model, and number of modules for most PV systems. DC-STC module ratings were identified for most systems by cross-referencing the information provided about the module type with the CSI’s 2008 List of Eligible Photovoltaic Modules, which identifies DC-STC ratings for most of the modules employed by systems funded through the ERP. The DC-STC module rating for each system was then multiplied by the number of modules to determine the total DC-STC rating for the system, as a whole. This approach was used to determine the DC-STC capacity rating for 86% of the systems in the ERP dataset. For the remaining systems, either the module data fields were incomplete, or the module could not be cross referenced with the CSI list, or the estimated DC-STC rating for the system was grossly inconsistent with the reported CEC-AC rating. In these cases, an average conversion factor of $1.200 W_{DC-STC}/W_{CEC-AC}$ was used, which was derived based on the other systems in the ERP dataset.

Self-Generation Incentive Program (SGIP): The data provided for the SGIP included data fields identifying module manufacturer and model (but not number of modules), and inverter manufacturer and model. DC-STC module ratings and DC-PTC module ratings (i.e., DC watts at PVUSA Test Conditions) were identified by cross-referencing the reported module type with the CSI’s 2008 List of Eligible Photovoltaic Modules. Similarly, the rated inverter efficiency for each project was identified by cross referencing the reported inverter type with the CSI’s 2008 List of Eligible Inverters, which identifies inverter efficiency ratings for most of the inverters employed by systems funded through the SGIP.³⁷ In cases where data on inverter manufacturer and model either was not provided or could not be matched with the CSI’s list, an inverter efficiency of 92.5% was used (the average inverter efficiency of systems in the SGIP dataset for which inverter efficiency ratings could be identified).

These pieces of information (module DC-STC rating, module DC-PTC rating, and inverter efficiency rating), along with the reported CEC-AC rating for the system, were used to estimate the system DC-STC rating according to the following:

$$\text{System}_{DC-STC} = (\text{System}_{CEC-AC} / \text{Inverter Eff.}) * (\text{Module}_{DC-STC} / \text{Module}_{DC-PTC})$$

This approach was used to determine the DC-STC capacity rating for 84% of the systems in the SGIP dataset. For the remaining systems, either the module data fields were incomplete, or the module could not be cross referenced with the CSI list, or the estimated DC-STC rating for the system was grossly inconsistent with the reported CEC-AC rating. In these cases, an average conversion factor of $1.204 W_{DC-STC}/W_{CEC-AC}$ was used, which was derived based on the other systems in the SGIP dataset.

³⁷ <http://www.gosolarcalifornia.org/equipment/inverter.php>

Appendix B: Detailed Sample Size Summaries

Table B-1. Program-Level Annual Installation Data, Based on Final Study Sample

State	Program Administrator(s) and Program Name		1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	Total	% of Sample	
AZ	AZ Public Service: Solar Partners Incentive Program	No. Systems	-	-	-	-	4	9	42	72	183	230	540	1.5%	
		MW	-	-	-	-	0.01	0.1	0.2	0.4	1.1	1.4	3.1	0.9%	
CA	CA Energy Commission: Emerging Renewables Program	No. Systems	39	178	213	1,236	2,243	2,964	4,542	3,869	6,119	5,864	27,267	73.7%	
		MW	0.2	0.7	0.9	4.8	9.8	15.1	22.4	20.5	34.2	34.4	143.0	39.4%	
	Pacific Gas & Electric, Southern Calif. Edison, Calif. Center for Sustainable Energy: Self Generation Incentive Program	No. Systems	-	-	-	-	17	99	160	212	160	153	801	2.2%	
		MW	-	-	-	-	2.4	15.1	19.6	30.9	30.9	33.6	132.6	36.5%	
	Pacific Gas & Electric, Southern Calif. Edison, Calif. Center for Sustainable Energy: California Solar Initiative	No. Systems	-	-	-	-	-	-	-	-	-	-	2,303	2,303	6.2%
		MW	-	-	-	-	-	-	-	-	-	-	14.3	14.3	3.9%
Los Angeles Dept. of Water & Power: Solar Incentive Program	No. Systems	-	3	4	103	232	150	24	61	15	-	-	592	1.6%	
	MW	-	0.01	0.1	0.6	1.5	4.7	1.6	1.8	0.3	-	-	10.6	2.9%	
CT	CT Clean Energy Fund: Solar PV and Onsite Renewable DG Programs	No. Systems	-	-	-	-	-	1	2	34	95	179	311	0.8%	
		MW	-	-	-	-	-	0.003	0.03	0.2	0.7	1.8	2.7	0.7%	
IL	IL Clean Energy Community Foundation: Renewable Energy Grant Programs	No. Systems	-	-	-	-	7	4	8	2	-	-	21	0.1%	
		MW	-	-	-	-	0.2	0.1	0.3	0.1	-	-	0.6	0.2%	
	IL Dept. of Commerce and Economic Opportunity: Renewable Energy Resources Rebate Program	No. Systems	-	9	2	5	5	-	3	3	42	76	145	0.4%	
		MW	-	0.02	0.03	0.2	0.2	-	0.05	0.003	0.1	0.2	0.7	0.2%	
MA	MA Technology Collaborative: Small Renewables Initiative	No. Systems	-	-	-	-	1	69	128	89	248	167	702	1.9%	
		MW	-	-	-	-	0.02	0.3	0.6	0.8	1.8	1.3	4.7	1.3%	
MD	MD Energy Administration: Solar Energy Grant Program	No. Systems	-	-	-	-	-	-	-	7	41	30	78	0.2%	
		MW	-	-	-	-	-	-	-	0.02	0.1	0.1	0.2	0.1%	
MN	MN State Energy Office: Solar Electric Rebate Program	No. Systems	-	-	-	-	1	9	23	12	23	37	105	0.3%	
		MW	-	-	-	-	0.002	0.02	0.1	0.03	0.1	0.2	0.4	0.1%	
NJ	NJ Clean Energy Program: Customer Onsite Renewable Energy Program	No. Systems	-	-	-	-	-	34	281	492	995	593	2,395	6.5%	
		MW	-	-	-	-	-	0.2	2.1	5.5	17.8	16.4	42.1	11.6%	
NY	NY State Energy Research and Development Authority: PV Incentive Program	No. Systems	-	-	-	-	-	43	98	95	190	329	755	2.0%	
		MW	-	-	-	-	-	0.2	0.5	0.6	1.1	2.0	4.4	1.2%	
OR	Energy Trust of Oregon: Solar Electric Program	No. Systems	-	-	-	-	-	54	135	87	126	198	600	1.6%	
		MW	-	-	-	-	-	0.1	0.4	0.3	0.5	0.9	2.3	0.6%	
PA	PA Sustainable Development Fund: Solar PV Grant Program	No. Systems	-	-	-	-	3	17	28	22	52	15	137	0.4%	
		MW	-	-	-	-	0.01	0.1	0.1	0.1	0.2	0.1	0.5	0.1%	
WI	WI Focus on Energy: Cash Back Rewards Program	No. Systems	-	-	-	-	10	18	23	27	64	98	240	0.6%	
		MW	-	-	-	-	0.02	0.03	0.1	0.1	0.2	0.5	0.9	0.2%	
Total		No. Systems	39	190	219	1,344	2,523	3,471	5,497	5,084	8,353	10,272	36,992	100%	
		MW	0.2	0.8	1.0	5.6	14.0	36.0	47.9	61.2	89.3	107.0	363.1	100%	

Table B-2. Sample Size by Installation Year and System Size Range

System Size Range	Installation Year										Total	% of Sample
	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007		
<u>No. Systems</u>												
0-5 kW	31	167	180	1,141	1,889	2,235	3,389	2,891	4,643	5,764	22,330	60%
5-10 kW	3	13	24	159	459	855	1,534	1,508	2,685	3,327	10,567	29%
10-100 kW	5	9	14	38	163	320	521	578	912	1,051	3,611	10%
100-500 kW	-	1	1	6	9	55	46	98	92	104	412	1%
>500 kW	-	-	-	-	3	6	7	9	21	26	72	0%
<i>Total</i>	<i>39</i>	<i>190</i>	<i>219</i>	<i>1,344</i>	<i>2,523</i>	<i>3,471</i>	<i>5,497</i>	<i>5,084</i>	<i>8,353</i>	<i>10,272</i>	36,992	100%
<u>Capacity (MW)</u>												
0-5 kW	0.1	0.4	0.4	3.1	5.0	6.3	9.8	8.6	14.4	18.5	66.5	18%
5-10 kW	0.02	0.1	0.2	1.0	3.1	5.7	10.4	10.5	18.8	23.1	72.9	20%
10-100 kW	0.1	0.2	0.3	0.6	2.9	7.3	12.4	14.3	19.0	21.5	78.7	22%
100-500 kW	-	0.1	0.1	0.9	1.3	11.4	10.4	20.4	20.3	23.3	88.2	24%
>500 kW	-	-	-	-	1.7	5.2	5.0	7.4	16.8	20.6	56.8	16%
<i>Total</i>	<i>0.2</i>	<i>0.8</i>	<i>1.0</i>	<i>5.6</i>	<i>14</i>	<i>36</i>	<i>47.9</i>	<i>61.2</i>	<i>89.3</i>	<i>107</i>	363.1	100%

Table B-3. Annual Average Installed Cost and Direct Cash Incentives, by PV Incentive Program and System Size

Program Administrator(s) and Program Name		Size Range (kW)	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	
AZ Public Service: Solar Partners Incentive Program	<10 kW	No. Systems	-	-	-	-	4	8	40	68	173	218	
		Avg. Cost	-	-	-	-	8.6	11.4	7.4	7.5	7.8	7.4	
		Avg. Incentive	-	-	-	-	3.3	3.5	3.7	3.7	3.6	3.0	
	10-100 kW	No. Systems	-	-	-	-	-	1	2	4	9	11	
		Avg. Cost	-	-	-	-	-	4.7	11.6	11.8	7.7	8.4	
		Avg. Incentive	-	-	-	-	-	2.2	3.8	3.7	3.7	3.3	
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	1	1
		Avg. Cost	-	-	-	-	-	-	-	-	-	9.3	8.9
		Avg. Incentive	-	-	-	-	-	-	-	-	-	4.1	4.0
CA Energy Commission: Emerging Renewables Program	<10 kW	No. Systems	34	168	200	1199	2104	2727	4185	3522	5492	5198	
		Avg. Cost	11.9	11.2	10.6	10.1	10.1	9.0	8.3	7.9	8.0	8.1	
		Avg. Incentive	3.2	3.1	3.0	4.1	4.2	3.8	3.3	2.8	2.5	2.3	
	10-100 kW	No. Systems	5	9	12	33	135	235	357	347	627	666	
		Avg. Cost	11.6	10.8	8.7	9.7	9.6	8.4	7.7	7.3	7.4	7.8	
		Avg. Incentive	3.2	3.0	2.8	4.2	4.2	3.9	3.4	2.8	2.5	2.3	
	>100 kW	No. Systems	-	1	1	4	4	2	-	-	-	-	
		Avg. Cost	-	8.8	7.4	6.2	7.6	8.2	-	-	-	-	
		Avg. Incentive	-	3.1	2.6	2.4	3.5	4.0	-	-	-	-	
Pacific Gas & Electric, Southern Calif. Edison, Calif. Center for Sustainable Energy: Self Generation Incentive Program	<10 kW	No. Systems	-	-	-	-	-	-	-	-	-	-	
		Avg. Cost	-	-	-	-	-	-	-	-	-	-	
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-	
	10-100 kW	No. Systems	-	-	-	-	11	56	114	118	86	63	
		Avg. Cost	-	-	-	-	9.4	8.1	8.2	7.6	7.6	7.3	
		Avg. Incentive	-	-	-	-	3.9	3.3	3.8	3.6	3.1	2.5	
	>100 kW	No. Systems	-	-	-	-	6	43	46	94	74	90	
		Avg. Cost	-	-	-	-	7.8	7.4	7.6	7.2	7.3	7.1	
		Avg. Incentive	-	-	-	-	3.9	2.5	3.2	3.5	3.3	2.5	
Pacific Gas & Electric, Southern Calif. Edison, Calif. Center for Sustainable Energy: California Solar Initiative	<10 kW	No. Systems	-	-	-	-	-	-	-	-	-	2136	
		Avg. Cost	-	-	-	-	-	-	-	-	-	8.1	
		Avg. Incentive	-	-	-	-	-	-	-	-	-	2.0	
	10-100 kW	No. Systems	-	-	-	-	-	-	-	-	-	163	
		Avg. Cost	-	-	-	-	-	-	-	-	-	8.0	
		Avg. Incentive	-	-	-	-	-	-	-	-	-	2.0	
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	4	
		Avg. Cost	-	-	-	-	-	-	-	-	-	7.1	
		Avg. Incentive	-	-	-	-	-	-	-	-	-	2.2	

Program Administrator(s) and Program Name		Size Range (kW)	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007
Los Angeles Dept. of Water & Power: Solar Incentive Program	<10 kW	No. Systems	-	3	3	100	223	118	16	51	12	-
		Avg. Cost	-	10.9	13.5	10.8	10.0	9.2	9.0	7.4	7.3	-
		Avg. Incentive	-	3.3	3.3	5.8	6.1	5.6	4.3	3.1	2.7	-
	10-100 kW	No. Systems	-	-	1	1	7	16	3	5	2	-
		Avg. Cost	-	-	6.3	10.1	9.6	9.2	12.4	7.3	6.9	-
		Avg. Incentive	-	-	3.4	5.2	6.0	5.9	4.9	2.9	2.7	-
	>100 kW	No. Systems	-	-	-	2	2	16	5	5	1	-
		Avg. Cost	-	-	-	8.3	9.2	9.2	8.0	8.3	7.9	-
		Avg. Incentive	-	-	-	5.7	6.2	6.0	5.9	2.9	2.7	-
CT Clean Energy Fund: Solar PV and Onsite Renewable DG Programs	<10 kW	No. Systems	-	-	-	-	-	1	1	33	88	164
		Avg. Cost	-	-	-	-	-	6.4	9.1	8.7	8.8	8.8
		Avg. Incentive	-	-	-	-	-	3.7	4.7	4.8	4.6	4.3
	10-100 kW	No. Systems	-	-	-	-	-	-	1	1	6	13
		Avg. Cost	-	-	-	-	-	-	15.3	8.3	8.1	8.1
		Avg. Incentive	-	-	-	-	-	-	6.7	4.6	4.7	4.1
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	1	2
		Avg. Cost	-	-	-	-	-	-	-	-	7.7	8.0
		Avg. Incentive	-	-	-	-	-	-	-	-	4.2	4.1
IL Clean Energy Community Foundation: Renewable Energy Grant Programs	<10 kW	No. Systems	-	-	-	-	2	2	3	-	-	-
		Avg. Cost	-	-	-	-	19.4	16.3	14.5	-	-	-
		Avg. Incentive	-	-	-	-	2.3	2.3	2.2	-	-	-
	10-100 kW	No. Systems	-	-	-	-	5	2	4	2	-	-
		Avg. Cost	-	-	-	-	15.8	16.4	12.7	10.6	-	-
		Avg. Incentive	-	-	-	-	2.0	2.1	2.2	5.3	-	-
	>100 kW	No. Systems	-	-	-	-	-	-	1	-	-	-
		Avg. Cost	-	-	-	-	-	-	13.3	-	-	-
		Avg. Incentive	-	-	-	-	-	-	2.0	-	-	-
IL Dept. of Commerce and Economic Opportunity: Renewable Energy Resources Rebate Program	<10 kW	No. Systems	-	9	1	1	-	-	2	3	42	74
		Avg. Cost	-	19.4	22.7	15.6	-	-	13.7	9.8	9.5	10.0
		Avg. Incentive	-	9.1	9.9	7.2	-	-	3.6	4.8	3.3	2.9
	10-100 kW	No. Systems	-	-	1	4	5	-	1	-	-	2
		Avg. Cost	-	-	18.6	11.9	14.4	-	4.4	-	-	3.3
		Avg. Incentive	-	-	7.3	6.6	7.4	-	3.5	-	-	0.8
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-
		Avg. Cost	-	-	-	-	-	-	-	-	-	-
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-

Program Administrator(s) and Program Name		Size Range (kW)	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007
MA Technology Collaborative: Small Renewables Initiative	<10 kW	No. Systems	-	-	-	-	-	64	118	73	228	158
		Avg. Cost	-	-	-	-	-	10.2	8.9	8.9	9.3	8.8
		Avg. Incentive	-	-	-	-	-	4.7	4.7	4.5	4.1	3.6
	10-100 kW	No. Systems	-	-	-	-	1	5	10	16	17	7
		Avg. Cost	-	-	-	-	16.4	12.6	11.6	10.1	10.5	9.4
		Avg. Incentive	-	-	-	-	13.6	9.3	7.7	7.1	5.8	6.6
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	3	2
		Avg. Cost	-	-	-	-	-	-	-	-	7.7	10.6
		Avg. Incentive	-	-	-	-	-	-	-	-	3.5	2.4
MD Energy Administration: Solar Energy Grant Program	<10 kW	No. Systems	-	-	-	-	-	-	-	7	40	29
		Avg. Cost	-	-	-	-	-	-	-	10.0	10.8	10.3
		Avg. Incentive	-	-	-	-	-	-	-	1.2	1.5	1.6
	10-100 kW	No. Systems	-	-	-	-	-	-	-	-	1	1
		Avg. Cost	-	-	-	-	-	-	-	-	9.5	7.4
		Avg. Incentive	-	-	-	-	-	-	-	-	0.1	0.4
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-
		Avg. Cost	-	-	-	-	-	-	-	-	-	-
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-
MN State Energy Office: Solar Electric Rebate Program	<10 kW	No. Systems	-	-	-	-	1	9	23	12	23	34
		Avg. Cost	-	-	-	-	5.8	9.5	7.5	9.2	8.1	9.2
		Avg. Incentive	-	-	-	-	2.3	2.2	2.1	2.1	2.1	2.0
	10-100 kW	No. Systems	-	-	-	-	-	-	-	-	-	3
		Avg. Cost	-	-	-	-	-	-	-	-	-	8.7
		Avg. Incentive	-	-	-	-	-	-	-	-	-	2.0
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-
		Avg. Cost	-	-	-	-	-	-	-	-	-	-
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-
NJ Clean Energy Program: Customer Onsite Renewable Energy Program	<10 kW	No. Systems	-	-	-	-	-	34	260	411	794	458
		Avg. Cost	-	-	-	-	-	9.3	8.8	8.4	8.3	8.4
		Avg. Incentive	-	-	-	-	-	6.1	6.0	5.8	5.4	4.8
	10-100 kW	No. Systems	-	-	-	-	-	-	20	73	168	104
		Avg. Cost	-	-	-	-	-	-	9.0	8.4	8.2	8.7
		Avg. Incentive	-	-	-	-	-	-	5.1	5.5	5.2	4.7
	>100 kW	No. Systems	-	-	-	-	-	-	1	8	33	31
		Avg. Cost	-	-	-	-	-	-	8.4	7.2	7.7	7.0
		Avg. Incentive	-	-	-	-	-	-	4.5	4.1	4.4	3.4

Program Administrator(s) and Program Name		Size Range (kW)	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	
NY State Energy Research and Development Authority: PV Incentive Program	<10 kW	No. Systems	-	-	-	-	-	37	89	80	169	298	
		Avg. Cost	-	-	-	-	-	9.2	9.3	8.9	8.9	8.8	
		Avg. Incentive	-	-	-	-	-	4.6	4.5	4.3	4.1	4.0	
	10-100 kW	No. Systems	-	-	-	-	-	6	9	15	21	31	
		Avg. Cost	-	-	-	-	-	9.2	8.2	8.4	9.0	8.9	
		Avg. Incentive	-	-	-	-	-	5.4	5.2	4.5	4.2	4.0	
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-	
		Avg. Cost	-	-	-	-	-	-	-	-	-	-	
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-	
Energy Trust of Oregon: Solar Electric Program	<10 kW	No. Systems	-	-	-	-	-	54	134	84	119	186	
		Avg. Cost	-	-	-	-	-	7.8	7.2	7.5	8.3	8.5	
		Avg. Incentive	-	-	-	-	-	4.5	4.0	3.1	2.0	2.0	
	10-100 kW	No. Systems	-	-	-	-	-	-	1	3	7	12	
		Avg. Cost	-	-	-	-	-	-	6.9	7.5	7.7	8.8	
		Avg. Incentive	-	-	-	-	-	-	2.2	1.6	1.1	1.3	
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-	
		Avg. Cost	-	-	-	-	-	-	-	-	-	-	
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-	
PA Sustainable Development Fund: Solar PV Grant Program	<10 kW	No. Systems	-	-	-	-	3	17	28	22	51	15	
		Avg. Cost	-	-	-	-	12.1	8.9	10.5	9.1	8.6	9.1	
		Avg. Incentive	-	-	-	-	4.6	4.4	4.2	4.0	4.4	5.7	
	10-100 kW	No. Systems	-	-	-	-	-	-	-	-	-	1	-
		Avg. Cost	-	-	-	-	-	-	-	-	-	8.4	-
		Avg. Incentive	-	-	-	-	-	-	-	-	-	3.5	-
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-	-
		Avg. Cost	-	-	-	-	-	-	-	-	-	-	-
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-	-
WI Focus on Energy: Cash Back Rewards Program	<10 kW	No. Systems	-	-	-	-	10	18	23	27	61	85	
		Avg. Cost	-	-	-	-	10.7	10.5	7.7	9.5	8.4	8.9	
		Avg. Incentive	-	-	-	-	3.2	2.6	2.1	2.4	2.5	1.9	
	10-100 kW	No. Systems	-	-	-	-	-	-	-	-	-	3	13
		Avg. Cost	-	-	-	-	-	-	-	-	-	8.0	7.9
		Avg. Incentive	-	-	-	-	-	-	-	-	-	2.8	2.1
	>100 kW	No. Systems	-	-	-	-	-	-	-	-	-	-	-
		Avg. Cost	-	-	-	-	-	-	-	-	-	-	-
		Avg. Incentive	-	-	-	-	-	-	-	-	-	-	-

Appendix C: Calculating After-Tax Cash Incentives and State and Federal Investment Tax Credits

Section 4 presents trends related to combined after-tax financial incentives (direct cash incentives from state/utility PV incentive programs plus state and Federal ITCs) and net installed costs after receipt of these incentives. Calculating this value required that several operations first be performed on the data provided by PV program administrators, as described below.

- 1. Segmenting Systems as Residential, Commercial, or Tax-Exempt.** Data provided by many of the programs did not explicitly identify whether the PV systems were owned by residential, commercial, or tax-exempt entities. Unless otherwise identified, we classified all systems <10 kW as residential and all systems >10 kW as commercial.
- 2. Estimating the After-Tax Value of Cash Incentives from State/Utility Incentive Programs.** Although the IRS has provided only limited guidance on the issue, it appears that, in most cases, cash incentives provided for commercial PV systems are considered Federally-taxable income. As such, the cash incentives provided for systems in the dataset identified as commercial PV were assumed to be taxed at a Federal corporate tax rate of 35%. The taxation of cash incentives for commercial PV at the state level may vary by state; for simplicity, we assume that all commercial PV systems are taxed at the “effective” state corporate tax rate, which accounts for the fact that state corporate taxes reduce the incentive-recipient’s Federally-taxable income. The effective state corporate tax rate applied to the cash incentive is equal to 65% (i.e., 1 minus 35%) of the nominal state corporate tax rate in 2007, which ranged from 6.60% to 9.99% among the 12 states in our dataset.³⁸

Cash incentives paid to residential PV system owners are exempt from Federal income taxes if the incentive is considered to be a “utility energy conservation subsidy,” per Section 136 of the Internal Revenue Code. Despite several IRS private letter rulings of potential relevance, uncertainty remains as to what exactly constitutes a “utility energy conservation subsidy.” Notwithstanding this uncertainty, we assume that cash incentives provided to all systems in the dataset identified as residential PV are exempt from Federal income taxes. The taxation of cash incentives for residential PV at the state level may vary by state, but for simplicity, we assume that all residential PV systems are also exempt from state income tax.

- 3. Estimating the Value of State ITCs.** We identified 5 of the 12 states in our dataset as having offered a state ITC for PV at some point from 1998-2007. Based on the information contained in Table C-1, we determined whether each project in the dataset was eligible for a state ITC, and if so, estimated the amount of the tax credit. In all cases, we assumed that the size of the state ITC was not impacted by any Federal ITC received. We did, however, account for the fact that state tax credits are financially equivalent to Federally-taxable income (since they increase the recipient’s Federally-taxable income by an amount equal to the size of the state tax credit). The net value of state ITCs was therefore reduced by 35% to reflect the offsetting increase in Federal income taxes.
- 4. Estimating the Value of Federal ITCs.** Projects in the dataset identified as residential PV and installed on or after January 1, 2006 were assumed to receive a Federal ITC equal to the lesser of 30% of the tax credit basis or \$2,000. Projects in the dataset identified as commercial PV are assumed to receive a Federal ITC equal to 10% of the tax credit basis if installed prior to January 1, 2006, or 30% of the tax credit basis if installed after that date.

³⁸ http://www.taxadmin.org/fta/rate/corp_inc.html

The tax credit basis on which the Federal ITC is calculated depends on whether cash incentives received by a project are Federally-taxable. If the cash incentives are Federally-taxable, as assumed for all commercial PV, then the Federal ITC is calculated based on the full installed cost of the system. If, on the other hand, the cash incentives are not Federally-taxable, as assumed for all residential PV, then the Federal ITC is calculated based on the installed cost minus the value of the tax-exempt cash incentives.

Table C-1: State ITC Details

State	Applicable Customers	System Size Cap	Applicable Period	Tax Credit Amount	Cap
AZ	Residential	None	1995-indefinite	25% of <i>pre-rebate</i> installed cost	\$1,000
	Non-Residential and Tax-Exempt	None	2006-2012	10% of <i>pre-rebate</i> installed cost	\$25,000
CA	All	200 kW	2001-2003	15% of <i>post-rebate</i> installed cost	None
	All	200 kW	2004-2005	7.5% of <i>post-rebate</i> installed cost	None
MA	Residential	None	1979-indefinite	15% of <i>pre-rebate</i> installed cost	\$1,000
NY	Residential	10 kW	1998-9/1/2006	25% of <i>post-rebate</i> installed cost	\$3,750
	Residential	10 kW	9/1/2006-indefinite	25% of <i>post-rebate</i> installed cost	\$5,000
OR	Residential	None	11/4/2005-indefinite	\$3/W based on rated capacity (DC-STC)*	\$6,000 up to 50% of <i>pre-rebate</i> installed cost
	Non-Residential and Tax-Exempt	None	1981-2006	35% of <i>pre-rebate</i> installed cost	\$10,000,000
	Non-Residential and Tax-Exempt	None	2007-2017	50% of <i>pre-rebate</i> installed cost (up to max. eligible cost**)	\$10,000,000

* Tax credit paid out over multiple years, with an annual limit of \$1,500/yr.

** Max. eligible cost varies by system size: currently \$9/W for systems up to 100 kW, ramping down linearly to \$7.50/W for systems >1,000 kW. The tax credit is paid out over five years.

Key Report Contacts

Ryan Wiser, Berkeley Lab
510-486-5474; RHWiser@lbl.gov

Galen Barbose, Berkeley Lab
510-495-2593; GLBarbose@lbl.gov

Carla Peterman, Berkeley Lab
cpeterman@berkeley.edu

Download the Report

<http://eetd.lbl.gov/ea/ems/re-pubs.html>

Disclaimer

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.



Lawrence Berkeley National Laboratory

Acknowledgments

For their support of this project, the authors thank Tom Kimbis and Charles Hemmeline of the U.S. DOE's Solar Energy Technologies Program, Larry Mansueti of the U.S. DOE's Office of Electricity Delivery and Energy Reliability, and Mark Sinclair of the Clean Energy States Alliance.

For providing information or reviewing elements of this paper, we thank: Julie Blunden (SunPower), Kathleen Bolcar (U.S. Department of Energy), Mark Bolinger (Lawrence Berkeley National Laboratory), Larry Burton (Sierra Pacific Power), Ron Celentano (Pennsylvania Sustainable Development Fund), Barry Cinnamon (Akeena), Sachu Constantine (California Public Utilities Commission), Nick Fugate (California Energy Commission), Bill Haas (formerly with the Illinois Department of Commerce and Economic Opportunity), B. Scott Hunter (New Jersey Board of Public Utilities), James Lee (California Energy Commission), Tyler Leeds (Massachusetts Technology Collaborative), Gabriela Martin (Illinois Clean Energy Community Foundation), David McClelland (Energy Trust of Oregon), Stacy Miller (Minnesota Office of Energy Security), Colin Murchie (SunEdison), Ray Myford (Arizona Public Service), Angela Perondi-Pitel (Connecticut Clean Energy Fund), Selya Price (National Renewable Energy Laboratory), Jeff Peterson (New York State Energy Research and Development Authority), Vishal Shah (Barclays Capital), Larry Sherwood (IREC), Mark Sinclair (Clean Energy Group), Mike Taylor (Solar Electric Power Association), Maria Ulrich (Maryland Energy Administration), and Niels Wolter (Wisconsin Focus on Energy). We also thank Anthony Ma for assistance with cover design, formatting, and production. Of course, the authors are solely responsible for any remaining omissions or errors.

Berkeley Lab's contributions to this report were funded by: the Office of Energy Efficiency and Renewable Energy (Solar Energy Technologies Program) and the Office of Electricity Delivery and Energy Reliability (Permitting, Siting and Analysis Division) of the U.S. Department of Energy under Contract No. DE-AC02-05CH11231; and the Clean Energy States Alliance.